

Sand Filter
 Operation and Maintenance Inspection Report
 City of Mebane, North Carolina

Project Name: _____
 City Project Number: _____
 Property PIN Number: _____
 BMP Name: _____
 BMP Owner: _____
 Owner Address: _____

 Owner Phone #: _____
 Owner Email: _____

Inspection Date: _____
 Recent Rainfall Date: _____
 Rainfall Depth (in): _____
 Inspector: _____
 Company: _____
 Phone #: _____
 Email: _____



Code Key:
 N/A = Not Applicable M = Monitor (potential for future problem)
 NP = Not a Problem WN = Work Needed

Potential Problem	Code	Comments
Entire BMP		
Trash/debris is present.		

Adjacent Pavement (if applicable)		
Sediment is present on the pavement surface.		
Other (describe)		

Perimeter of sand filter		
Areas of bare soil and/or erosive gullies have formed.		
Vegetation is too short or too long.		
Other (describe)		

Flow diversion structure		
The structure is clogged.		
The structure is damaged.		
Other (describe)		

Forebay or pretreatment area		
Sediment has accumulated to a depth of >6 inches.		
Erosion has occurred.		
Weeds are present.		
Other (describe)		

Potential Problem	Code	Comments
Filter bed and underdrain collection system		
Water is ponding on the surface for >24 hours after a storm		
Other (describe)		

Outlet device		
Clogging has occurred		
Device is damaged		
Other (describe)		

Receiving Water		
Erosion or other signs of damage at the outlet.		
Other (describe)		

Miscellaneous		
Access		
Vandalism		
Signage (if applicable)		
Other (describe)		

ADDITIONAL COMMENTS

PHOTOGRAPHS

Attach digital photographs of the site and structural BMPs including a caption describing the photo.